

Classification Report

Number	20-000066-PR01 (NW-A05-02-en-03)
Owner	Fero V bvba Den Heuvel 20 2970 Schilde Belgium
Product	roof window
Designation	Shipping name: DR all sizes
Details	roof window: Manufacturer Fero V bvba, - Schilde; Designation DRK (40 x 60 cm); Material Steel - painted or powder coated; Note Installation at 35° roof pitch; Type of opening Top-hung case-ment; Opening direction Outwards; Overall dimensions (W x H) 600 mm x 878 mm
Special features	

Result **)

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C3/B3

Watertightness according to EN 12208:1999-11



Class: 9A

Basis *)

EN 14351-1:2006+A2:2016-09
) and corresponding national versions
(e.g. DIN EN)

Test report: 20-000066-PR01 PB-
A05-02-de-03

Replaces Nachweis:
20-000066-PR01 NW-A05-02-en-
02 dated 08.12.2021

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

**) Decision rule: For conformity assessment, the determined measurement results were assumed to be error-free values.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

12.01.2022



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Philipp Dumproff, B.Eng.
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 89A-7F861